

ADDENDUM

Project Name: Utility Tunnel Extension

Addendum No.: Two (2)

Project Designation: SUU University Cedar City, Utah

Date: April 20, 2005

From: WHW ENGINEERING INC.
1354 EAST 3300 SOUTH SUITE 200
SALT LAKE CITY, UTAH 84106

To: VALLEY DESIGN & CONSTRUCTION
825 EAST 3000 NORTH, SUITE D
LAYTON UTAH 84041

KOH MECHANICAL
1273 WEST 12400 SOUTH
RIVERTON, UTAH 84065

GARFF CONSTRUCTION
2820 WEST 500 SOUTH
SALT LAKE CITY, UTAH 84104

BARCLAY MECHANICAL
595 WEST 100 NORTH
MANTI, UTAH 84642

McCLOUGH ENGINEERING & CONSTRUCTION
1567 EAST STRATFORD AVENUE
SALT LAKE CITY, UTAH 84106

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated **March 31, 2005** and Addendum Number **1** dated **April 15, 2005**, and Addendum Number **2** dated **April 20, 2005**. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of **2** page(s) and the attached drawing(s), **1** Sheet.

I - CHANGES TO PRIOR ADDENDA:

Item I-1. N/A

II - CHANGES TO BIDDING REQUIREMENTS:

Item II-1. N/A

III - CHANGES TO AGREEMENT & OTHER CONTRACT FORMS:

Item III-1. N/A

IV - CHANGES TO CONDITIONS OF THE CONTRACT:

Item IV-1. N/A


V - CHANGES TO SPECIFICATIONS:

Item V-1. N/A

VI - CHANGES TO DRAWINGS:

Item VI-1. Drawing D1/ME503 from Addendum #1 shall be changed as shown on the attached drawing D1/ME503. The drawing was changed to change the routing of the geotextile fabric and the pit run gravel to 1 ½" diam. and minus clean rock. See also the addition of the words "and 18" of gravel to top note. See also the new location of the 6" diam. drain pipe.

END of ADDENDUM



D1

TUNNEL SECTION FILL REQUIREMENTS

SCALE: NONE

MECHANICAL ADDENDUM #2

ME503